

AUG 24 1982

August 18, 1982

Mr. Dave Porter  
Porter's So-Lo Market  
1475 North National  
Springfield, MO 65802

Re: So-Lo Market - 2424 West Division

Dear Dave:

On August 16, 1982, Mr. Bob Corson with City Sanitary Services and I met at the So-Lo Store located at 2424 West Division. Our purpose was to determine the source of water surfacing at the northwest corner of the building near the street. After putting dye in several sewer drains in the building, we determined the produce sink drain and the floor drain by the ice machine in the warehouse are draining to the area by the street mentioned above.

Please be advised that surfacing water is in violation of the Springfield City Code, Section 24-2. Therefore, this letter is to serve as notification that you have 30 days from the date of this letter to correct this problem.

Your prompt attention to this matter will be appreciated.

Sincerely

Ron Lawson  
Food Control Specialist

RL:SW

2424 W. Division